

Proprietary cold rolled joists at 600mm centres


Galvanised steel or white Plastisol faced Vermiculux lined two piece casements to exposed columns to give one hour fire protection

RHS column supporting main beam

Wired mat cavity barriers required to ceiling voids exceeding 10.0 metres in any direction

1200 or 600 x 600mm white fissured one hour fire rated mineral board tile suspended ceiling fixed approx 100mm below joists

Min clear 100 below decking support joists

		Innovation House Daleside Road Nottingham NG2 4DH	
		Tel 0115 9110243 Fax 0115 9110246	
© RDA Projects Ltd 2006			
Client		Various	
Project		Mezzanine Floor Fire Protection	
Title		One Hour Fire Protection Ceiling & Column Casements With Cavity Barriers	
Scale	1:5	Date	31/01/08
Drawn by	RJB	Drawing No	SK05
Approval		Construction	<input checked="" type="checkbox"/> As built